



# **KITTITAS COUNTY**

## **DEPARTMENT OF PUBLIC WORKS**

### **MEMORANDUM**

**TO:** All Staff  
**FROM:** Public Works Plan Review Team  
**DATE:** February 18, 2025  
**SUBJECT:** SX-25-00001 Debauppte

<b>ACCESS</b>	<ol style="list-style-type: none"><li>1. An approved access permit shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering an existing access.</li><li>2. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.</li><li>3. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards.</li><li>4. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application. (JS)</li></ol>
<b>ENGINEERING</b>	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CP)
<b>FLOOD</b>	Parcel #628235 is not mapped within a FEMA identified special flood hazard area (100-year floodplain). A floodplain development permit is not required for the proposed project. (SC)
<b>WATER MITIGATION/ METERING</b>	Groundwater mitigation options are not currently available for parcels within the Gold Creek basin for compliance with KCC 13.35.027. An alternative cistern water system is being proposed for the potable water serving the single-family residence that must meet KCC 13.25 standards. (SC)
<b>AIRPORT</b>	No Comments. (JS)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.