



KITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: July 17, 2025
SUBJECT: SX-25-00006 Mosley

ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CBP)
FLOOD	The activity proposed on this property is within the 500-year floodplain. This area is identified as an area of moderate flood hazard risk. A floodplain development permit is only required for development within the 100-year floodplain or floodway. (SC)
WATER MITIGATION/ METERING	No comments. (SC)
AIRPORT	No Comments. (RC)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.