



KITITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: March 16, 2026
SUBJECT: SX-26-00004 Reising

ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CBP)
FLOOD	A portion of parcel #776334 is mapped within the FEMA identified special flood hazard area (1% annual chance flood zone). If possible, all development should remain outside of the special flood hazard area to reduce risk and avoid mandatory flood insurance purchase requirements. A flood permit is not required for the project as proposed. (SC)
WATER MITIGATION/ METERING	No comments. (SC)
AIRPORT	No Comments. (RC)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.