



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: June 25, 2026
SUBJECT: SX-26-00009 Graddon

ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CBP)
FLOOD	Parcel #951888 is mapped within the FEMA identified special flood hazard area (100-year floodplain and floodway). Flood permit FD-26-00007 has been issued for the proposed structure. (SC)
WATER MITIGATION/ METERING	No comments. (SC)
AIRPORT	No Comment. (RC)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.