



# KITITAS COUNTY

## DEPARTMENT OF PUBLIC WORKS

---

### MEMORANDUM

---

**TO:** All Staff  
**FROM:** Public Works Plan Review Team  
**DATE:** November 26, 2025  
**SUBJECT:** SX-25-00019 Rayner East

<b>ENGINEERING</b>	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CBP)
<b>FLOOD</b>	This property is located within the FEMA identified special flood hazard area (1 percent annual chance flood zone) and will be within the floodway when the Easton Reach LOMR is approved. All activities within the floodplain require a floodplain development permit. All construction, including structures that are exempt from a building permit, must follow the guidelines within KCC 14.08. Structures may be subject to mandatory flood insurance purchase requirements. (SC)
<b>WATER MITIGATION/ METERING</b>	No comments. (SC)
<b>AIRPORT</b>	No Comments. (RC)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.