

**WENGER SHORT PLAT (SP-07-00007)
COMPLIANCE DOCUMENT**

PRELIMINARY APPROVAL CONDITIONS	APPLICANT RESPONSE	STAFF REVIEW
<p>1) BOTH SHEETS OF THE FINAL MYLARS SHALL REFLECT SHORT PLAT NUMBER SP-07-00007 AND AN ACCURATE LEGAL DESCRIPTION SHALL BE SHOWN ON THE FACE OF THE FINAL PLAT. ENGINEERS AND SURVEYORS NEED TO BE COGNIZANT OF ALL OF THE REQUIREMENTS RELATED TO FINAL PLATS (KCC 16.20) AND SURVEY DATA AND DEDICATIONS (KCC 16.24). THE FINAL PLAT MUST BE SUBMITTED IN FULL CONFORMANCE WITH THESE CHAPTERS OF KITTITAS COUNTY CODE: <u>NON-COMPLIANT MYLARS WILL BE REJECTED AND RETURNED TO THE APPLICANT.</u></p>	<p>SHORT PLAT NUMBER HAS BEEN ADDED TO FINAL SHORT PLAT.</p> <p>SHORT PLAT IS IN FULL CONFORMANCE WITH COUNTY CODE.</p>	<p>SP-07-00007 on Face of Final Plat</p>
<p>2) ENVIRONMENTAL AND STATUTORY REVIEW MAY BE REQUIRED FOR ALL CURRENT AND FUTURE DEVELOPMENT, CONSTRUCTION, AND IMPROVEMENTS. THE APPLICANT AND/OR ALL FUTURE OWNERS OF ANY LOT OR LOTS WITHIN THIS SUBDIVISION ARE RESPONSIBLE FOR COMPLIANCE WITH ALL APPLICABLE LOCAL, STATE, AND FEDERAL RULES, REQUIREMENTS, CODES, AND REGULATIONS. IT IS INCUMBENT UPON SAID APPLICANTS AND FUTURE OWNERS TO INVESTIGATE FOR, AND OBTAIN FROM THE APPROPRIATE AGENCY OR THEIR REPRESENTATIVE, ALL REQUIRED PERMITS, LICENSES, AND APPROVALS FOR ANY DEVELOPMENT, CONSTRUCTION, AND/OR IMPROVEMENTS THAT OCCUR WITHIN THE BOUNDARIES OF THIS SUBDIVISION.</p>	<p>NOTED</p>	<p>OK Here</p> 
<p>3) ALL WATER PROPOSED TO BE USED MUST BE OBTAINED FROM A WATER BUDGET NEUTRAL SOURCE AND MEET CONDITIONS OF KCC 13.35.</p>	<p>SEE MITIGATION WATER ALLOCATION DOCUMENT AFN# 201805180082 (COPY OF DOCUMENT WILL BE INCLUDED WITH THE SUBMITTAL OF THIS COMPLIANCE DOCUMENT)</p>	<p>Recorded Document Submitted</p>
<p>4) THE CURRENT YEAR'S TAXES MUST BE PAID IN FULL ON ALL TAX PARCELS INVOLVED IN THIS LAND USE ACTION AS REQUIRED BY WASHINGTON STATE LAW (RCWS 84.40-042 & 84.56.345).</p>	<p>TAXES WILL BE PAID IN FULL FOR 2018</p>	<p>Taxes not yet paid, No MBSW to check</p>
<p><u>5) THE FOLLOWING PLAT NOTES SHALL BE RECORDED ON THE FINAL MYLAR DRAWINGS:</u></p> <p>A) ALL DEVELOPMENT MUST COMPLY WITH INTERNATIONAL FIRE CODE.</p>	<p>OK - SEE NOTE 11 ON SHEET 2 OF 3 OF FINAL SHORT PLAT.</p>	<p>Plat note listed</p>
<p>B) ALL WATER PROPOSED TO BE USED MUST BE OBTAINED FROM A WATER BUDGET NEUTRAL SOURCE AND MEET CONDITIONS OF KCC 13.35.</p>	<p>OK - SEE NOTE 12 ON SHEET 2 OF 3 OF FINAL SHORT PLAT.</p>	<p>Plat note listed</p>

**WENGER SHORT PLAT (SP-07-00007)
COMPLIANCE DOCUMENT**

<p>C) ENVIRONMENTAL AND STATUTORY REVIEW MAY BE REQUIRED FOR ALL CURRENT AND FUTURE DEVELOPMENT, CONSTRUCTION, AND IMPROVEMENTS. THE APPLICANT AND/OR ALL FUTURE OWNERS OF ANY LOT OR LOTS WITHIN THE SUBDIVISION ARE RESPONSIBLE FOR COMPLIANCE WITH ALL APPLICABLE LOCAL, STATE, AND FEDERAL RULES, REQUIREMENTS, CODES, AND REGULATIONS. IT IS INCUMBENT UPON SAID APPLICANTS AND FUTURE OWNERS TO INVESTIGATE FOR, AND OBTAIN FROM THE APPROPRIATE AGENCY OR THEIR REPRESENTATIVE, ALL REQUIRED PERMITS, LICENSES, AND APPROVALS FOR ANY DEVELOPMENT, CONSTRUCTION, AND IMPROVEMENTS THAT OCCUR WITHIN THE BOUNDARIES OF THIS SUBDIVISION.</p>	<p>OK – SEE NOTE 13 ON SHEET 2 OF 3 OF FINAL SHORT PLAT</p>	<p>Plat Note Listed</p>
<p>6) SHOULD GROUND DISTURBING OR OTHER ACTIVITIES RELATED TO THE PROPOSED SHORT PLAT RESULT IN THE INADVERTENT DISCOVERY OF CULTURAL OR ARCHAEOLOGICAL MATERIALS, WORK SHALL BE STOPPED IN THE IMMEDIATE AREA AND CONTACT BE MADE WITH THE WASHINGTON STATE DAHP. WORK SHALL REMAIN SUSPENDED UNTIL THE FIND IS ASSESSED AND APPROPRIATE CONSULTATION IS CONDUCTED. SHOULD HUMAN REMAINS BE INADVERTENTLY DISCOVERED, AS DICTATED BY WASHINGTON STATE RCW 27.44.055, WORK SHALL BE IMMEDIATELY HALTED IN THE AREA AND CONTACT MADE WITH THE CORONER AND LOCAL LAW ENFORCEMENT IN THE MOST EXPEDITIOUS MANNER POSSIBLE.</p>	<p>NOTED</p>	<p>OK</p>
<p>7) REQUIREMENTS SUBMITTED BY KITTITAS COUNTY PUBLIC WORKS: A) TIMING OF IMPROVEMENTS: THIS APPLICATION IS SUBJECT TO THE KITTITAS COUNTY ROAD STANDARDS, DATED 9/6/05. THE FOLLOWING CONDITIONS APPLY AND MUST BE COMPLETED PRIOR TO THE ISSUANCE OF A BUILDING PERMIT FOR ANY OF THE STRUCTURES WITHIN THE PLAT. A PERFORMANCE BOND OR ACCEPTABLE FINANCIAL GUARANTEE MAY BE USED, IN LIEU OF THE REQUIRED IMPROVEMENTS, PER THE CONDITIONS OUTLINED IN THE CURRENT KITTITAS COUNTY ROAD STANDARDS.</p>	<p>NOTED</p>	<p>OK</p>

**WENGER SHORT PLAT (SP-07-00007)
COMPLIANCE DOCUMENT**

<p>B) PRIVATE ROAD CERTIFICATION: PRIVATE ROADS SERVING ANY OF THE LOTS WITHIN THIS DEVELOPMENT SHALL BE INSPECTED AND CERTIFIED BY A LICENSED PROFESSIONAL ENGINEER FOR CONFORMANCE WITH KITTITAS COUNTY ROAD STANDARDS, 9/6/05 EDITION. KITTITAS COUNTY PUBLIC WORKS SHALL REQUIRE THIS ROAD CERTIFICATION TO BE COMPLETED PRIOR TO THE ISSUANCE OF A BUILDING PERMIT FOR ANY OF THE STRUCTURES WITHIN THE PROPOSED PLAT.</p>	<p>NOTED</p>	<p>OK</p>
<p>C) ROAD VARIANCE: THIS SHORT PLAT IS SUBJECT TO THE CONDITIONS OF ROAD VARIANCE 14-09, WHICH ALLOWS A REDUCED ROAD AND EASEMENT WIDTH BUT REQUIRES A REVISED AGREEMENT FROM USBR PRIOR TO FINAL APPROVAL.</p>	<p>NOTED</p>	<p>No Revised agreement submitted</p>
<p>D) FINAL PLAT: THE FOLLOWING ITEMS MUST BE SHOWN ON THE FINAL PLAT:</p> <ul style="list-style-type: none"> i) 100-YEAR FLOODPLAIN ii) SHORELINE JURISDICTION iii) BIG CREEK iv) KRDL LATERAL BOUNDARIES v) EASEMENT AND DRIVEWAY SERVING PARCEL 616536 	<ul style="list-style-type: none"> i) SEE SHEET 1 OF 3 ii) SEE SHEET 1 OF 3 iii) SEE SHEET 1 OF 3 iv) SEE SHEET 1 OF 3 v) SEE SHEET 1 OF 3 & SEE NOTE 14 ON SHEET 2 OF 3 	<p>Floodplain boundary: Flood plain needs to be shown, not flood zone boundaries. Shorelines Not OK- Shows OHWM but not shoreline buffer Big Creek: property line boundary halfway into creek shown, but centerline does not continue Easement not shown as continuing to P# 616536</p>
<p>E) FLOODPLAIN: A BUILDING SITE MUST BE DESIGNATED OUTSIDE OF THE 100-YEAR FLOODPLAIN. IF ANY CONSTRUCTION OF RESIDENTIAL OR NON-RESIDENTIAL BUILDINGS TAKES PLACE WITHIN THE 100-YEAR FLOODPLAIN, BASE FLOOD ELEVATIONS MUST BE DETERMINED FOR THE ENTIRE SUBDIVISION.</p>	<p>NOTED</p>	<p>Floodplain boundaries not shown to make this determination</p>
<p>F) PRIVATE ROAD IMPROVEMENTS: WITHIN THE PLAT, ACCESS SHALL BE CONSTRUCTED AS A LOW-DENSITY PRIVATE ROAD. SEE KITTITAS COUNTY ROAD STANDARDS, 9/6/05 EDITION.</p> <ul style="list-style-type: none"> i) ACCESS EASEMENTS SHALL BE A MINIMUM OF 60' WIDE. THE ROADWAY SHALL HAVE A MINIMUM WIDTH OF 20', WITH 1' SHOULDERS, FOR A TOTAL WIDTH OF 22'. ii) MINIMUM CENTERLINE RADIUS WILL BE 60'. iii) THE SURFACE REQUIREMENT IS FOR A MINIMUM GRAVEL SURFACE DEPTH OF 6". iv) MAXIMUM GRADE IS 12%. v) STOPPING SITE DISTANCE, REFERENCE AASHTO. vi) ENTERING SITE DISTANCE, REFERENCE AASHTO. vii) MAINTENANCE OF DRIVEWAY APPROACHES SHALL BE THE RESPONSIBILITY OF THE OWNER WHOSE 	<p>NOTED</p>	<p>Will happen at access permit</p>

**WENGER SHORT PLAT (SP-07-00007)
COMPLIANCE DOCUMENT**

<p>PROPERTY THEY SERVE. THE COUNTY WILL NOT MAINTAIN ACCESSES.</p> <p>viii) ANY FURTHER SUBDIVISION OR LOTS TO BE SERVED BY PROPOSED ACCESS MAY RESULT IN FURTHER ACCESS REQUIREMENTS.</p> <p>ix) ALL ROADS LOCATED WITHIN THIS DEVELOPMENT OR ROADS THAT PROVIDE ACCESS TO THIS DEVELOPMENT SHALL BE CONSTRUCTED TO CURRENT COUNTY ROAD STANDARDS UNLESS ANY OTHER MAINTENANCE AGREEMENTS, FOREST SERVICE ROAD EASEMENTS OR STATE EASEMENTS REQUIRE HIGHER ROAD STANDARDS. THE HIGHER OF THE ROAD STANDARDS SHALL APPLY.</p> <p>x) ALL EASEMENT SHALL PROVIDE FOR AASHTO RADIUS AT THE INTERSECTION OF COUNTY ROAD.</p> <p>xi) A PAVED APRON SHALL BE CONSTRUCTED AT THE INTERSECTION OF THE PROPOSED PRIVATE INTERSECTION AND THE COUNTY ROAD RIGHT OF WAY.</p>	<p align="center">NOTED</p>	<p align="center">Will address at access permit</p>
<p>G) CUL-DE-SAC: A CUL-DE-SAC TURN-AROUND HAVING AN OUTSIDE RIGHT-OF-WAY OR EASEMENT DIAMETER OF AT LEAST 110 FEET SHALL BE CONSTRUCTED AT THE CLOSED END OF ALL DEAD-END ROADS SERVING 3 OR MORE LOTS. THE DRIVING SURFACE SHALL BE AT LEAST 96 FEET IN DIAMETER. CUL-DE-SACS MUST ALSO CONFORM TO THE REQUIREMENTS SPECIFIED BY THE 2009 INTERNATIONAL FIRE CODE. CONTACT THE FIRE MARSHAL REGARDING ANY ADDITIONAL CUL-DE-SAC REQUIREMENTS.</p>	<p align="center">NOTED</p>	<p align="center">Will address at access permit</p>
<p>H) JOINT-USE DRIVEWAY: A JOINT-USE ACCESS SHALL SERVE NO MORE THAN TWO TAX PARCELS. SEE KITTITAS COUNTY ROAD STANDARDS, 9/6/05 EDITION.</p> <p>i) ACCESS EASEMENTS SHALL BE A MINIMUM OF 20' WIDE. THE ROADWAY WIDTH SHALL HAVE A MINIMUM WIDTH OF 12'.</p> <p>ii) THE SURFACE REQUIREMENT IS FOR A MINIMUM GRAVEL SURFACE DEPTH OF 6".</p> <p>iii) MAINTENANCE OF DRIVEWAY APPROACHES SHALL BE THE RESPONSIBILITY OF THE OWNER WHOSE PROPERTY THEY SERVE. THE COUNTY WILL NOT MAINTAIN ACCESSES.</p> <p>iv) ANY FURTHER SUBDIVISION OR LOTS TO BE SERVED BY PROPOSED ACCESS MAY RESULT IN FURTHER ACCESS REQUIREMENTS.</p>	<p align="center">NOTED</p>	<p align="center">Will address at access permit</p>

**WENGER SHORT PLAT (SP-07-00007)
COMPLIANCE DOCUMENT**

<p>I) SINGLE-USE DRIVEWAY: A SINGLE-USE ACCESS SHALL SERVE NO MORE THAN ONE LOT. SEE KITTITAS COUNTY ROAD STANDARDS, 9/6/05 EDITION.</p> <p>i) THE ROADWAY SHALL BE A MINIMUM OF 8' WIDE WITH GRAVEL SURFACE.</p> <p>ii) MAINTENANCE OF DRIVEWAY APPROACHES SHALL BE THE RESPONSIBILITY OF THE OWNER WHOSE PROPERTY THEY SERVE. THE COUNTY WILL NOT MAINTAIN ACCESSES.</p> <p>iii) ANY FURTHER SUBDIVISION OR LOTS TO BE SERVED BY PROPOSED ACCESS MAY RESULT IN FURTHER ACCESS REQUIREMENTS.</p>	<p>NOTED</p>	<p>Will address at access permit</p>
<p>J. PRIVATE ROAD MAINTENANCE AGREEMENT: THE APPLICANT SHALL MEET ALL APPLICABLE CONDITIONS OF ANY PRE-ESTABLISHED OR REQUIRED PRIVATE ROAD MAINTENANCE AGREEMENTS.</p>	<p>NOTED</p>	<p>Will address at access permit</p>
<p>K. LOT CLOSURE: IT IS THE RESPONSIBILITY OF THE PROFESSIONAL LICENSED SURVEYOR (PLS) TO ENSURE THE LOT CLOSURES ARE CORRECT AND ACCURATE.</p>	<p>TO BE SUBMITTED WITH THIS DOCUMENT</p>	<p>Closures submitted</p>
<p>L. ACCESS PERMIT: AN APPROVED ACCESS PERMIT SHALL BE REQUIRED FROM THE DEPARTMENT OF PUBLIC WORKS PRIOR TO CREATING ANY NEW DRIVEWAY ACCESS OR PERFORMING WORK WITHIN THE COUNTY ROAD RIGHT OF WAY.</p>	<p>NOTED</p>	<p>Will address at access permit</p>
<p>M. ADDRESSING: CONTACT THE KITTITAS COUNTY RURAL ADDRESSING COORDINATOR AT (509) 962-7523 TO OBTAIN ADDRESSES PRIOR TO OBTAINING A BUILDING PERMIT. A PARCEL CANNOT RECEIVE A BUILDING PERMIT OR UTILITIES UNTIL SUCH PARCEL IS IDENTIFIED WITH A 911 ADDRESS.</p>	<p>NOTED</p>	<p>Will address at access permit</p>
<p>N. FIRE PROTECTION: CONTACT THE KITTITAS COUNTY FIRE MARSHAL REGARDING ANY ADDITIONAL ACCESS REQUIREMENTS FOR EMERGENCY RESPONSE.</p>	<p>NOTED</p>	<p>Will address at access permit</p>
<p>O. MAILBOX PLACEMENT: THE U.S. POSTAL SERVICE REQUIRES THAT PRIVATE ROADS WITH 6 OR MORE RESIDENCES INSTALL USPS APPROVED CLUSTER BOX UNITS (CBUS) AT A SAFE LOCATION AT THE MOUTH OF THE PRIVATE ROAD. CONTACT YOUR LOCAL POST OFFICE FOR LOCATION AND ADDITIONAL DESIGN REQUIREMENTS BEFORE BEGINNING CONSTRUCTION.</p>	<p>NOTED</p>	<p>Will be addressed at building</p>