

Subdivision Comments

To: Jeremy Johnston, Planning Official
From: Jesse Cox, Environmental Health Supervisor
Date: Aug 15, 2019
RE: SPF-19-00003

Thank you for the opportunity to comment on the above mentioned project regarding water and septic requirements to comply with Kittitas County Public Health Department's Environmental Health requirements.

Findings

On Site Sewage

- The SPF-19-00003 Jerke Short Plat project is served by existing on-site septic systems.

Water

- This short plat is served by well ID AFH655 with a 2 party shared well water users agreement.
- Metering is required for all new uses of domestic water for residential well connections and usage must be recorded in a manner consistent with Kittitas County Code Chapter 13.35.027 and Ecology regulations. There are no additional requirements.
- The approval of this division of land provides no guarantee that use of water under the ground water exemption (RCW 90.44.050) for this plat or any portion thereof will not be subject to curtailment by the Department of Ecology or a court of law (settlement agreement).

A Additional Information Required

No information is required for further review prior to any determinations leading to recommendation for approval.