Kittitas County Public Health Department

SITE EVALUATION APPLICATION INSPECTION RESULTS

507 N Nanum St., Suite 102, Ellensburg, WA 98926
509-962-7515
https://www.co.kittitas.wa.us/health/

Account Name: Gregersen, Chris

Account # OE-25-00057

443 RICHARDS RD CLE ELUM CLE ELUM, WA 98922

Parcel # 21053

Inspector	Inspection Type	Inspection Date	Status	Comments
Dan Suggs	SITE EVALUATION INSPECTION	04/28/2025	SATISFACTORY	

Group	Task Description	Status	Comments
	SL 1: Depth/Soil Type/Structure/Color	VERIFIED	0-72 type 4/moderate blocky/light brown
	SL 2: Depth/Soil Type/Structure/Color	VERIFIED	0-32 type 4/moderate blocky/light brown 32-55 type 3/medium sand with cobbles/light brown
	SL 3: Depth/Soil Type/Structure/Color	N/A	
	SL 4: Depth/Soil Type/Structure/Color	N/A	
	Minimum Horizontal Separations	YES	Wells (100')
	Field Observations	YES	Well #BQH 629

LOT A2
TEST PITS
WELL
BIG CREEK RD
443 RICHARDS RD
LOT A1
Image © 2025 Airbus