



To Protect and Promote the Health and the Environment of the People of Kittitas County

To: Zach Torrance-Smith

From: Dan Suggs, Environmental Health Specialist
(509) 962-7024, dan.suggs@co.kittitas.wa.us

Date: January 21, 2025

Subject: Short Plat Application SP-25-00002 Sageview

1. Drinking Water:

- The existing individual well on proposed lot A2 does not appear to meet the required 50-foot property line setback. If the existing well does not meet this setback requirement, the applicant may request an exemption from the current regulations.

2. Wastewater:

- Soil logs must be performed and recorded for each new lot within the proposed short plat.

These comments are based on the information provided in the short plat application materials. Any revisions to the proposal may result in changes to Public Health's comments.



507 N. Nanum Street, St. 102 · Ellensburg, WA 98926
T: 509.962.7515 · F: 509.962.7581
www.co.kittitas.wa.us/health/