



# **KITTITAS COUNTY**

## **DEPARTMENT OF PUBLIC WORKS**

### **MEMORANDUM**

**TO:** All Staff  
**FROM:** Public Works Plan Review Team  
**DATE:** November 15, 2024  
**SUBJECT:** SE-24-00032 Stoliarenko

<b>ACCESS</b>	No comments. (JS)
<b>ENGINEERING</b>	<ol style="list-style-type: none"><li>1. Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080).</li><li>2. It is the applicant's responsibility to work with WDFW to ensure that bridge design meets their requirements.</li></ol>
<b>SURVEY</b>	There are no survey comments regarding this application. (JT)
<b>TRANSPORTATION CONCURRENCY</b>	No transportation concurrency required for this project. (KAH)
<b>FLOOD</b>	The project is not within a FEMA identified special flood hazard area (100-year floodplain). (SC)
<b>WATER MITIGATION/ METERING</b>	No comments. (SC)
<b>AIRPORT</b>	No comments. (JS)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.