



KITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Public Works Plan Review Team
DATE: June 22, 2021
SUBJECT: SE-21-00010 Zimmer

SEPA Application Comments

- The project does not propose any alterations to the existing access. There are no additional access requirements at this time.
- An engineered grading permit is required for any grading exceeding 500 cubic yards of material. This permit will be required unless exemptions listed in Kittitas County Code 14.05.060 apply, such as: "12. Construction activities performed by a state or federal agency with oversight of a licensed civil or geotechnical engineer."
- The proposed activity is within the FEMA-identified 100-year floodplain. Since this activity is for a Federal project on Federal land, a local floodplain development permit is not required. Please note that Executive Order 11988 requires Federal agencies comply with National Flood Insurance Program regulations.

Please contact Kittitas County Public Works (509) 962-7523 with any questions.