

# KITTITAS COUNTY

## DEPARTMENT OF PUBLIC WORKS


---

### MEMORANDUM


TO: Jeff Watson  
FROM: Christina Wollman, Planner II *sw*  
DATE: December 1, 2010  
SUBJECT: Kittitas County Fire District #2 PF-10-00004

The Department of Public Works has reviewed the Public Facilities Permit for Fire District #2 and has the following comments:

- A. The site is currently addresses as 890 Cleman Road. The approach is currently constructed to agricultural standards. With the construction of the fire station, the approach must be improved to meet commercial standards as shown in WSDOT Design Manual Exhibit 1340-5 (attached). Prior to performing any work within the county right-of-way, an access permit must be applied for from Public Works.



Profile Controls



Condition	A	B	C	D	E	F	G	H	J
Primary SU and less	—	—	[1]	30	15	—	—	30	[1]
Primary combination Vehicle WB 40	—	—	[1]	65	15	—	—	55	[1]
	4	25	[2]	50	15	7	25	45	[1]
Primary combination Vehicle WB 50 and doubles	—	—	[1]	70	20	—	—	50	[1]
	4	25	[3]	55	20	—	—	50	[1]

Notes:

- [1] Normal shoulder width (see Chapter 1140).
- [2] Normal shoulder width less A.
- [3] For larger vehicles, use turning templates (see Chapter 1310).
- [4] Vertical curves between the shoulder slope and the road approach grade not to exceed a 3/4-inch hump or a 2-inch depression in a 10-ft cord.

General:

Values given are in ft.

Road Approach Design Template D1  
Exhibit 1340-5