



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

January 9, 2008

Anne Watanabe
PO Box 687
Roslyn, WA 98926

RE: Tumbling Ridge PUD

Dear Ms. Watanabe,

Per Kittitas County Code 16.12.020 (A), the Director of Public Works can require road plans and profiles prior to preliminary approval. Due to the history and known issues of Jenkins Drive, road plans and profiles shall be required for review to ensure that Jenkins Drive can meet the requirement of KCC 12, Kittitas County Road Standards. This information shall be required prior to preliminary approval.

Proposed road plans and profiles shall be prepared by a licensed civil engineer and shall be submitted on standard 22" x 36" sheets for review. The scale shall be 1" = 100' horizontal and 1" = 10' vertical, sheet one.

Sincerely,

A handwritten signature in cursive script that reads "CWollman".

Christina Wollman
Planner

cc: Dan Valoff, Community Development Services