


Noah Goodrich

From: Holly Duncan
Sent: Friday, December 01, 2006 8:17 AM
To: Noah Goodrich
Subject: SPPLANNING



PUBLIC HEALTH DEPARTMENT

www.co.kittitas.wa.us/health/

Administration

**Community Health Services
Health Promotion Services**
507 N. Nanum Street, Ste 102
Ellensburg, WA 98926
Phone: (509) 962-7515
Fax: (509) 962-7581

Environmental Health
411 North Ruby Street, S
Ellensburg, WA 98926
Phone (509) 962-7698
Fax (509) 962-7052

November 30, 2006

Noah Goodrich, Staff Planner
Kittitas County Community Development Services
411 N. Ruby St., Suite 2
Ellensburg, WA. 98926

RE: Sieber Short Plat (SP-06-93)

Dear Mr. Goodrich,

Thank you for the opportunity to comment on the above referenced project. The applicant states on the face of the plat map that a Group B water system will be used to serve the four proposed lots. In March of this year I approved a Group B water system to serve eight lots in the same area for Mr. Sieber. It appears that the configuration of the lots has changed from the time I approved the Sieber water system. At this point there is some confusion as to the well that will serve these proposed lots. He could be planning to add these four lots onto the existing system. If that is not the case a source site inspection needs to be performed by Environmental Health to approve the placement of the well that is to serve these four lots,(WAC 246-291). Our records indicate that both soil and water availability information is needed.

If you need any further information, please feel free to contact me. Thank you for your time.

Sincerely,

Holly Duncan