Dosier SP-07-46

3105

File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 28710

Water Right Permit No. D

(1) OWNER: Name Tom Dozier Address PAYS

(2) LOCATION OF WELL: County KITTITAS S ¼ NW ¼ Sec. 1 T 19 N., R 15 W.M.

(2a) STREET ADDDRESS OF WELL (or nearest address)

(3) PROPOSED USE: [X] Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ] DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned [ ] New well [X] Method: Dug [ ] Bored [ ] Deepened [ ] Cable [ ] Driven [ ] Reconditioned [ ] Rotary [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches. Drilled 140 feet. Depth of completed well 140 ft.

(6) CONSTRUCTION DETAILS:
Casing Installed: 6" Diam. from 0 ft. to 120 ft.
Welded [X] Liner Installed [ ] Threaded [ ] " Diam. from ft. to ft.
" Diam. from ft. to ft.

Perforations: Yes [ ] No [ ]
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [ ] No [ ]
Manufacturer's Name
Type Model No.
Diam. Slot size from ft. to ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes [ ] No [ ] Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 20 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes [ ] No [ ]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level
Static level 10 ft. below top of well Date 5-18-90
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [ ] If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Airtest 8-10 gal./min. with stem set at 135 ft. for 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [ ] No [ ]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
DIRT	0	4
BROWN CLAY	4	20
CEMENTED GRAVEL	20	45
BLUE SANDSTONE - GRAVEL	45	60
LARGE COBBLES WITH CLAY	60	110
BROWN SANDSTONE WITH GRAVEL	110	130
LOOSE SAND & GRAVEL	130	140



Work started 5-15 19 90 Completed 5-18 19 90

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Bach Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address Rt 5 Box 1010 Ellensburg WA
(Signed) Mike Bach (WELL DRILLER) License No. 22
Contractor's Registration No. BACHBDC173N4 Date 6-1 19 90

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20 (10/87) -1329-

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.