



KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N Ruby St., Suite 2, Ellensburg, WA 98926

Office (509-962-7657)

PROPANE INSTALLATION CRITICAL AREAS EVALUATION

DATE: _____

NAME: _____

INSTALLER: _____

TAX PARCEL #: _____

SITE ADDRESS: _____

FLOOD ZONE: _____

The International Fire Code requires the following setbacks from property lines, buildings, and public ways for propane tanks:

125-500 gallon tanks..... 10 feet

501-2,000 gallon tanks..... 25 feet

**** A single tank installations up to 1,200 gallons may be reduced to 10 feet ****

See note (3) on Fire Marshal LPG Tank Set Back Handout **