



To Protect and Promote the Health and the Environment of the People of Kittitas County

Subdivision Comments

To: Kelly Bacon, CDS Planner 1
From: Holly Erdman, Environmental Health Specialist 2
Date: 1/12/2022
RE: SPF-XX-000XX Connor Short Plat

Thank you for the opportunity to comment on the above-mentioned project regarding water and septic requirements to comply with Kittitas County Public Health Department's Water Resources and Environmental Health requirements.

Findings

On Site Sewage

Finding 1

Any on-site septic systems that are to be utilized for wastewater management must adhere to the standards set by both the Washington Administrative Code, and Kittitas County Code. In accordance with KCC 13.04.090, a minimum of one soil log for each proposed lot where individual sewage disposal systems are contemplated must be completed. If community drain fields are to be utilized, soil logs must be done in the proposed locations of each(See Conditions A-2).

Water

Finding 1

The existing Group B water system must be approved and expanded to serve 2 of the proposed lots of this plat prior to final plat signature.

The proposed Group B water system must have a well drilled and a Group B water system approved to be able to serve 8 connections with a public water system ID# issued prior to obtaining final plat signature.



To Protect and Promote the Health and the Environment of the People of Kittitas County

B	Final Plat Review & Recording (Prior to Final Plat Approval)
----------	---

Soil logs were done on each proposed lot.

Group B water system expansion must be applied for the existing 6 connection Group B and expanded to serve 2 more lots.

For remaining 8 lots, a Group B water system must be approved with a state identification number issued prior to obtaining final plat signature.