

# Exhibit B

**From:** Joe Dietzel joe.dietzel@co.kittitas.wa.us

**Subject:** Thorp Landing Subdivision

**Date:** April 26, 2023 at 2:49 PM

**To:** Chad Bala bala.ce@gmail.com, kcf1@fairpoint.net, Darren Higashiyama darren.higashiyama@co.kittitas.wa.us, Jeremiah Cromie jeremiah.cromie@co.kittitas.wa.us

JD

Good Afternoon,

After further review of the information regarding the 5 acre lots to be built on Thorp Landing Lane, the fire flow requirements and the fire hydrant system requirements are hereby waived. The lots are required to be sprinklered from the irrigation canal(s), the lots are low hazard WUIC scores, and the lots do not have a high ability to expose to other structures in the event of a fire. Thank you for your time.

*Joseph A Dietzel*

Kittitas County

Deputy Fire Marshal

509-962-7657

[joe.dietzel@co.kittitas.wa.us](mailto:joe.dietzel@co.kittitas.wa.us)



**To schedule inspections:** <https://www.co.kittitas.wa.us/cds/building/inspection-request.aspx> OR call

(509) 962-7694

**To view permit or inspection status:** <https://co-kittitas-wa.smartgovcommunity.com/ApplicationPublic/ApplicationHome>

**If this is a public records request, please go to:**

<https://www.co.kittitas.wa.us/request/default.aspx>

The information transmitted by this e-mail is intended only for the person named and those specifically named. If you are not the named addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake. If you are not the named addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake. Please do not forward to anyone else. Message id: 38eb45... public id: 0240577 20230426