

Subdivision Comments

To: Jeremiah Cromie, CDS Planner II

From: Dan Suggs, Environmental Health Specialist II

Date: 5/11/22

RE: SP-22-00004 Willard

Thank you for the opportunity to comment on the above-mentioned project regarding water and septic requirements to comply with Kittitas County Public Health Department's Water Resources and Environmental Health requirements.

Findings

On Site Sewage

Finding 1

Any on-site septic systems that are to be utilized for wastewater management must adhere to the standards set by both the Washington Administrative Code, and Kittitas County Code. In accordance with KCC 13.04.090, a minimum of one soil log for each proposed lot where individual sewage disposal systems are contemplated must be completed.

Water

Finding 1

The proposed short plat indicates the applicant will develop a Group B water system to serve the project. The location of the well site must be approved prior to drilling and a Group B water system must be approved by the Kittitas County Public Health Department. The applicant must prove legal and physical availability of water for all new uses of water on proposed lots.

A	Additional Information Required (Prior to Preliminary Plat Approval)
----------	---

No additional information required



B	Final Plat Review & Recording (Prior to Final Plat Approval)
----------	---

On-site sewage

A soil log must be done on each proposed lot.

Water

A Group B public water system must be approved by the Kittitas County Public Health Department with a public water system ID# issued by the Washington State Department of Health, Division of Drinking Water.

C	Final Plat Notes
----------	-------------------------

No additional information required

