



STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

1250 W Alder St • Union Gap, WA 98903-0009 • (509) 575-2490

March 12, 2019

Dusty Pilkington  
Kittitas County Community Development  
411 N. Ruby St., Suite 2  
Ellensburg, WA 98926

Re: ACU-19-00001

Dear Dusty Pilkington:

Thank you for the opportunity to comment during the optional determination of nonsignificance process for the ATT Teanaway Cell Tower project, proposed by Washington Department of Natural Resources. We have reviewed the documents and have the following comments.

**AIR QUALITY**

This proposal does not specify whether it includes an emergency generator(s). If it does, note that stationary emergency internal combustion engines (emergency generators) with aggregate brake horsepower greater than 500 brake horsepower require a preconstruction air quality permit. For information regarding air permit applicability and/or process, please contact **Ryan Vicente** at (509) 454-7899 or [ryan.vicente@ecy.wa.gov](mailto:ryan.vicente@ecy.wa.gov).

Sincerely,

Gwen Clear  
Environmental Review Coordinator  
Central Regional Office  
(509) 575-2012  
[crosepacoordinator@ecy.wa.gov](mailto:crosepacoordinator@ecy.wa.gov)

201901124

