Jeff,

After conducting a review of the above named project, I have the following comments:

- Ensure that boundary line adjustments do not infringe upon existing structures, to include propane tanks, etc.
- Creation of any additional roads or access must comply with the International Fire Code.
- All future development must comply with the International Fire Code.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office. 509-962-7000.

Sincerely,

Brenda Larsen Kittitas County Fire Marshal 509-962-7000

From: Jeff Watson Sent: Monday, July 26, 2010 10:37 AM To: Brenda Larsen Subject: FW: SG-10-00012 Cle Elum Ridge

Haven't seen this one did I miss it...?

From: Jeff Watson
Sent: Wednesday, June 30, 2010 4:28 PM
To: Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan
Subject: SG-10-00012 Cle Elum Ridge

SG-10-00012 Cle Elum Ridge

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeff Watson Planner I

Kittitas County Community Development Services 411 N. Ruby Street, Suite 2 Ellensburg, WA 98926 jeff.watson@co.kittitas.wa.us P: 509.933.8274 F: 509.962.7682



All e-mail sent to this address will be received by the Kittitas County e-mail system and may be subject to Public Disclosure under RCW Chapter 42.56 and is subject to archiving and review by someone other than the recipient.

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14