

From: [Brenda Larsen](#)
To: [Jeff Watson](#)
Subject: RE: LL-08-00004, 05, 06, 07
Date: Monday, November 29, 2010 4:18:08 PM

Jeff,

Re: Cabin Mountain Tree Farm Large Lot Subdivision (LL-08-00006) & Cabin Mountain Tracts Large Lot Subdivision (LL-08-00007)

Dear Mr. Watson:

After conducting a review of the above named projects, I have the following comments:

- The access road shall meet the International Fire Code requirements for fire apparatus access.
- Further subdivision of these properties will result in requirements for fire flow as required in Appendix B of the International Fire Code.
- All future development must comply with the International Fire Code.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at 509-962-7000.

Sincerely,

Brenda Larsen
Kittitas County Fire Marshal
509-962-7000

From: Jeff Watson
Sent: Wednesday, October 20, 2010 1:44 PM
To: Brenda Larsen
Subject: LL-08-00004, 05, 06, 07

I now see why I didn't have those comments in the first two applications click [here](#) to view all applications if your heart desires.

Jeff Watson
Planner I

Kittitas County Community Development
Services

411 N. Ruby Street, Suite 2
Ellensburg, WA 98926
jeff.watson@co.kittitas.wa.us
P: 509.933.8274
F: 509.962.7682



"Building Partnerships-Building Communities"

All e-mail sent to this address will be received by the Kittitas County e-mail system and may be subject to Public Disclosure under RCW Chapter 42.56 and is subject to archiving and review by someone other than the recipient.

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14