

### Source of Water Supply

The Phase 2 Division 4 (The Cabins at The Farm) development will be served by the Suncadia Water Company, a Class A water system regulated by the Department of Health. The Suncadia Water Company has included this parcel in their comprehensive planning and has provided a water availability letter.

### Phase 2 Division 4 Water System Description

The preliminary transmission and distribution system for The Cabins at The Farm plat is illustrated on the enclosed Conceptual Utility Exhibit. The water for the development will be supplied by the MPR water reservoirs. The reservoirs are located in the northeast section of the MPR.

The plat will provide an 8-inch diameter water main that loops thru the site and connects to the 18-inch Swiftwater Drive.

All homes are to be fire sprinkled on site. Hydrants will be placed at a maximum of 500 feet spacing. Fire flow calculations were developed using a flow of 1500 gallons per minute at 20 pounds per square inch (psi) pressure. The Resort is served by Fire District 7. A fire station for - District 7 is located on the Resort at 31 Firehouse Road, at the northwest intersection of Bullfrog Road.