



Memo

To: Kaycee Hathaway, CDS
From: Holly Myers, Environmental Health Supervisor
Date: 2/10/2015
RE: LP-07-00040 Big Buck Ridge

Thank you for the opportunity to comment on the abovementioned long plat.

The submittal indicates the applicant intends to set up a Group B water system to serve 14 lots. Individual onsite sewage systems will need to meet Kittitas County code requirements.

Prior to receiving **final approval** for long plats in Kittitas County, applicants shall be required to show written findings of the adequacy of potable water supplies. Kittitas County Public Health Department (KCPHD) requires the following as evidence of written findings of a potable water supply:

1. **GROUP B PUBLIC WATER SYSTEM:** Applicants shall provide the following for Group B Public Water Systems:
 - a. A well site inspection performed by KCPHD staff and the well(s) drilled
 - b. Complete and submit a Group B Public Water System Workbook to either KCPHD for water systems with 3-9 connections or Washington State Department of Health (DOH) for water systems with 10-14 connections;
 - c. Contract with an approved Kittitas County Satellite Management Agency.

All infrastructure for the Group B water system including the well house and storage tanks must be completed or the developer/owner can bond for completion. Final approval of the Group B Public Water System including issuance of the public water system ID number from DOH is required prior to recommendation by KCPHD for final plat approval.

