



June 4, 2008

Mackenzie Moynihan, Staff Planner  
Kittitas County Community Development Services  
411 N. Ruby St., Suite 2  
Ellensburg, WA. 98926

RE: F & G Performance Based Cluster Plat (LP-08-19)

Dear Ms. Moynihan,

Thank you for the opportunity to comment on the above referenced project. The applicant states that a Group A public water system will be used to serve the proposed 51-lot plat. Based on the Revised Code of Washington (RCW) 90.44.050, a water right is required for public systems exceeding 14 connections.

A well site inspection must be performed to approve the site where the well is to be located. The water system must be approved by the Washington State Department of Health in Spokane prior to final plat approval.

The file indicates soil log information is needed on each lot.

If you need any further information, please feel free to contact me. Thank you for your time.

Sincerely,



Holly Duncan  
Environmental Health Specialist

