

To: Kittitas County Community Development Services
Mackenzie Moynihan, Staff Planner

Subject: F & G Performance Based Cluster Plat (LP-08-19)

Referencing the proposed cluster plat, Kittitas County Fire District 7 has specific concerns related to this development. Outlined in the notice is the proposal for a class A water system, but no mention of hydrants to protect this development. Being remotely located and backed up against the mountains in an urban wild-land environment with additional developments in planning, the fire district strongly requests that an appropriate water system be developed to provide fire flows for a hydrant system that is evenly spaced no more than 600 feet in separation. The system should meet minimum fire flows for residential development.

Thank you for allowing the fire district to comment on this development.

Russ Hobbs, Chief
Kittitas County Fire District 7
PO Box 777
South Cle Elum, WA 98943

