



To Protect and Promote the Health and the Environment of the People of Kittitas County

June 20, 2008

Mackenzie Moynihan  
Community Development Services



Dear Mackenzie:

Thank you for the opportunity to comment on B & J Preliminary Plat, LP-08-00021. I recommend that this plat utilize a Group B water system to serve the 7 lots. A well site inspection must be performed to approve the site where the well is. The group B workbook and all associated paperwork must be turned in and the system design approved prior to final plat approval.

Soil logs are required for each lot where installation of a septic system is intended


I look forward to assisting you if you have further questions or concerns.

Sincerely,

A handwritten signature in black ink that reads "Holly Myers".

Holly Myers  
Environmental Health Director  
Kittitas County Public Health  
(509)962-7584

**Kittitas County  
Public Health Department**  
507 N. Nanum Street, Suite 102  
Ellensburg, WA 98926  
T: 509.962.7515  
F: 509.962.7581



[www.co.kittitas.wa.us/health/](http://www.co.kittitas.wa.us/health/)

**Environmental  
Health Services**  
411 North Ruby Street, Suite 3  
Ellensburg, WA 98926  
T: 509.962.7698  
F: 509.962.7052