



# KITTITAS COUNTY

## DEPARTMENT OF PUBLIC WORKS

### MEMORANDUM

TO: Community Development Services

FROM: Kelly Bacon, Engineer Technician I *KB*

DATE: December 1, 2017

SUBJECT: Swauk Valley Ranch Conservation Plat LP-17-00007

#### The following shall be conditions of preliminary approval:

1. Washington State Department of Transportation: Provide copy of access approval/permit from WSDOT allowing for the change in use.
2. Private Road and Driveway Easements: The private road and driveway easements shall be clearly depicted on the face of the plat in accordance with the driveway standards as shown in the Kittitas County Code 12: section 12.04.080 table 4-4 Private Road Minimum Design Standards.
3. Timing of Improvements: This application is subject to the latest revision of the Kittitas County Road Standards, dated 12/15/15.
  - Road Variance RV-17-06 for Swauk Valley Ranch was approved
  - A bond has been received by Public Works for the work to be performed.
4. Turnaround: When a road extends more than 150' from the centerline of a County road or other publicly maintained road or serves more than three lots, a turnaround shall be provided. The turnaround shall be a cul-de-sac for roads serving five or more lots/units. The turnaround may be a hammerhead for roads serving four or less lots/units or for a land use development activity occurring prior to the end of the road. Cul-de-sac and hammerhead designs must conform to the specifications of the International Fire Code. A cul-de-sac shall have an easement diameter of at least 110 feet and a driving surface of at least 96 feet in diameter.
5. Driveways: A driveway shall serve no more than two tax parcels. See Kittitas County Road Standards, 12/15/15 edition.
  - a. New access easements shall be a minimum of 30' wide. The roadway width shall have a minimum width of 12' if the length of the driveway is less than 150', or 16' if the length of the driveway is more than 150'.
  - b. Maximum grade shall be 15%.
  - c. Crushed surface depth per WSDOT standards.

Page 1 of 3

411 N. Ruby St. Suite 1  
Ellensburg, WA 98926

TEL (509) 962-7523  
FAX (509) 962-7663

G:\PLANNING\Development\Plats\Swauk Valley Ranch LP-17-00007\LP-17-00007 Planning Comments Preliminary.doc

- d. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.
  - e. Any further subdivision or lots to be served by proposed access may result in further access requirements.
6. Plat Notes: Plat notes shall reflect the following:
- a. Kittitas County will not accept private roads for maintenance as public streets or roads until such streets or roads are brought into conformance with current County Road Standards and formally adopted by the Kittitas County Board of County Commissioners.
  - b. Maintenance of the access is the responsibility of the property owners who benefit from its use.
  - c. An approved access permit will be required from the Department of Public Works prior to creating any new driveway access or performing work within the county road right-of-way.
  - d. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards.
  - e. A public utility easement 10 feet in width is reserved along all lot lines. The 10 foot easement shall abut the exterior plat boundary and shall be divided 5 feet on each side of interior lot lines. Said easement shall also be used for irrigation
7. Plat Approvals: All plats must show the acceptance signature of the County Engineer. The acceptance block shall be as follows (per KCC 16.24.170):

EXAMINED AND APPROVED  
This \_\_\_\_ day of \_\_\_\_, A.D., 20\_\_.

---

Kittitas County Engineer

8. Private Road Maintenance Agreement: The applicant shall meet all applicable conditions of any pre-established or required Private Road Maintenance Agreements.
9. Lot Closure: It is the responsibility of the Professional Licensed Surveyor (PLS) to ensure the lot closures are correct and accurate.
10. Access Permit: An approved access permit shall be required from the Department of Public Works prior to creating any new driveway access or performing work within the county road right of way.
11. Addressing: Contact the Kittitas County Rural Addressing Coordinator at (509) 962-7523 to obtain addresses prior to obtaining a building permit. A parcel cannot receive a building permit or utilities until such parcel is identified with a 911 address.
12. Fire Protection: Contact the Kittitas County Fire Marshal regarding any additional access requirements for Emergency Response.

13. Mailbox Placement: The U.S. Postal Service requires that private roads with 6 or more residences install USPS approved Cluster Box Units (CBUs) at a safe location at the mouth of the private road. Contact your local Post Office for location and additional design requirements before beginning construction.