

From: Dusty Pilkington
To: ["demain1@fairpoint.net"](mailto:demain1@fairpoint.net)
Subject: FW: CB-16-00006 Halloin
Date: Thursday, September 01, 2016 1:58:00 PM

Mr. Halloin,

One small revision needs to be made to the site plan for the parcel combination application. See below the message from Environmental Health.

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926
(509) -962-7079
dusty.pilkington@co.kittitas.wa.us

From: Holly Duncan
Sent: Thursday, September 01, 2016 1:32 PM
To: Dusty Pilkington
Cc: Holly Myers
Subject: RE: CB-16-00006 Halloin

The site plan makes it appear that the well will be the required 100 feet or more away from the proposed drainfield however, the distance needs to be indicated on the site plan.

From: Dusty Pilkington
Sent: Tuesday, August 30, 2016 11:35 AM
To: Kelly Bacon; Lucas Huck; Holly Myers; Holly Duncan; Josh Hink; Nelson, Jennifer L (DFW)
Subject: CB-16-00006 Halloin

[CB-16-00006 Halloin \(County Departments\)](#) [CB-16-00006 Halloin \(County Website Links\)](#)

—
Kelly, Hollys, and Josh, and other interested parties,

Could you please review this application and submit comments for the decision. Control Click on the hyperlink above (or go to the attachment tab in EDEN). Comment period for this application ends on September 14, 2016.
Thanks,

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926
(509) -962-7059
dusty.pilkington@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14