Rachael,

After review of this proposal and the additional information submitted, public health has no issues with the project. The only comment I have is the applicant references a shared well located on 581334 "which supplies water to all three parcels." A shared well serves a maximum of 2 dwellings. Three lots or more are classified as a Group B water system and must be approved as such.

Thank you,

Holly

From: Rachael Stevie (CD) <rachael.stevie.cd@co.kittitas.wa.us>
Sent: Tuesday, March 17, 2020 8:11 AM
To: Holly Erdman <Holly.erdman@co.kittitas.wa.us>
Subject: FW: Updated Map and Project Narrative

Hi Holly, here is the updated site map the applicant provided. The black shaded square represents the well. Will this work?

Let me know. Thank you!

Ranhard Stevie

Planner I Kittitas County Community Development Services 411 N. Ruby Street; Suite 2 Ellensburg, WA 98926 509-962-7637 rachael.stevie.cd@co.kittitas.wa.us

From: Sarah Hilsenberg <<u>src2063@gmail.com</u>>
Sent: Tuesday, March 17, 2020 7:19 AM
To: Rachael Stevie (CD) <<u>rachael.stevie.cd@co.kittitas.wa.us</u>>
Subject: Updated Map and Project Narrative

Good Morning Rachael,

Attached is an updated map with the well location and exact measurements from the house and the property line. I've also added measurements and further explanation to the project narrative, also attached. Please let me know if more is needed.

Notice: Email sent to Kittitas County may be subject to public disclosure as required by law. message id: 38eb45916c6dcbdac24bb8719d004a14