

From: [Toni Berkshire](#)
To: [Jeremiah Cromie](#)
Subject: RE: PF-22-00002 KCFD #7 - Notice of Application
Date: Thursday, October 6, 2022 12:45:46 PM
Attachments: [image001.png](#)

Hi Jeremiah,
Code Enforcement does not have a comment for this project. Thank you.

Regards,

Toni Berkshire, CCEO

Kittitas County Code Enforcement
Community Development Services
411 N Ruby Street, Suite 2
Ellensburg, WA 98926
(509) 962-7001



Please Note: If this is a Public Records Request, please go to <https://www.co.kittitas.wa.us/request/default.aspx> and fill out a request for public records through the GovQA portal.

From: Jeremiah Cromie <jeremiah.cromie@co.kittitas.wa.us>

Sent: Thursday, October 6, 2022 11:33 AM

To: Kim Dawson <kim.dawson@co.kittitas.wa.us>; George Long <long@kittcom.org>; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Toni Berkshire <toni.berkshire@co.kittitas.wa.us>; PublicHealth Inspectors <PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Codi Fortier <codi.fortier@co.kittitas.wa.us>; 'enviroreview@yakama.com' <enviroreview@yakama.com>; 'corrine_camuso@yakama.com' <corrine_camuso@yakama.com>; 'jessica_lally@yakama.com' <jessica_lally@yakama.com>; 'noah_oliver@yakama.com' <noah_oliver@yakama.com>; 'casey_barney@yakama.com' <casey_barney@yakama.com>; 'kozj@yakamafish-nsn.gov' <kozj@yakamafish-nsn.gov>; 'matj@yakamafish-nsn.gov' <matj@yakamafish-nsn.gov>; 'barh@yakamafish-nsn.gov' <barh@yakamafish-nsn.gov>; 'separegister@ecy.wa.gov' <separegister@ecy.wa.gov>; 'tebu461@ecy.wa.gov' <tebu461@ecy.wa.gov>; 'lowh461@ECY.WA.GOV' <lowh461@ECY.WA.GOV>; 'FormerOrchards@ecy.wa.gov' <FormerOrchards@ecy.wa.gov>; 'wendy.neet@ecy.wa.gov' <wendy.neet@ecy.wa.gov>; 'crosepa@ecy.wa.gov' <crosepa@ecy.wa.gov>; 'Scott.Downes@dfw.wa.gov' <Scott.Downes@dfw.wa.gov>; 'Jennifer.Nelson@dfw.wa.gov' <Jennifer.Nelson@dfw.wa.gov>; 'Elizabeth.Torrey@dfw.wa.gov' <Elizabeth.Torrey@dfw.wa.gov>; 'sepa@dahp.wa.gov' <sepa@dahp.wa.gov>; 'jorgenja@cwu.edu' <jorgenja@cwu.edu>; 'nelmsk@cwu.edu' <nelmsk@cwu.edu>; Jeremy Larson <jeremy.larson@co.kittitas.wa.us>; Steph Mifflin <stephanie.mifflin@co.kittitas.wa.us>;

From: [Adam Osbekoff](#)
To: [Jeremiah Cromie](#)
Subject: RE: PF-22-00002 KCFD #7 - Notice of Application
Date: Thursday, October 6, 2022 7:50:17 PM

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Hello Jeremiah

The Snoqualmie Tribe [Tribe] is a federally recognized sovereign Indian Tribe. We were signatory to the Treaty of Point Elliott of 1855; we reserved certain rights and privileges and ceded certain lands to the United States. As a signatory to the Treaty of Point Elliot, the Tribe specifically reserved among other things, the right to fish at usual and accustomed areas and the “privilege of hunting and gathering roots and berries on open and unclaimed lands” off-reservation throughout the modern-day state of Washington.

Thank you for the opportunity to review and comment. Based on the information provided and our understanding of the project and its APE, we would recommend an archeological review performed for this project. This is in an area the Snoqualmie Tribe considers culturally significant and has a high probability to have unknown archaeological deposits. If any archaeological work is performed, we request notification. An IDP should not be used in lieu of archeological investigation. Cultural and archaeological resources are non-renewable and are best discovered prior to ground disturbance.

Thank you

Adam Osbekoff

From: Jeremiah Cromie [mailto:jeremiah.cromie@co.kittitas.wa.us]
Sent: Thursday, October 6, 2022 11:33 AM
To: Kim Dawson <kim.dawson@co.kittitas.wa.us>; George Long <long@kittcom.org>; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Toni Berkshire <toni.berkshire@co.kittitas.wa.us>; PublicHealth Inspectors <PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Codi Fortier <codi.fortier@co.kittitas.wa.us>; 'enviroreview@yakama.com' <enviroreview@yakama.com>; 'corrine_camuso@yakama.com' <corrine_camuso@yakama.com>; 'jessica_lally@yakama.com' <jessica_lally@yakama.com>; 'noah_oliver@yakama.com' <noah_oliver@yakama.com>; 'casey_barney@yakama.com' <casey_barney@yakama.com>; 'kozj@yakamafish-nsn.gov' <kozj@yakamafish-nsn.gov>; 'matj@yakamafish-nsn.gov' <matj@yakamafish-nsn.gov>; 'barh@yakamafish-nsn.gov' <barh@yakamafish-nsn.gov>; 'separegister@ecy.wa.gov' <separegister@ecy.wa.gov>;

Sent: Friday, October 7, 2022 12:43 PM

To: Jeremiah Cromie <jeremiah.cromie@co.kittitas.wa.us>

Subject: RE: PF-22-00002 KCFD #7 - Notice of Application

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Hello Jeremiah

The Snoqualmie Indian Tribes Department of Archaeology and Historic Preservation have minor cultural resource concerns and defer to more proximate tribes.

Thank you

Adam Osbekoff

From: Jeremiah Cromie [<mailto:jeremiah.cromie@co.kittitas.wa.us>]

Sent: Thursday, October 6, 2022 11:33 AM

To: Kim Dawson <kim.dawson@co.kittitas.wa.us>; George Long <long@kittcom.org>; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Toni Berkshire <toni.berkshire@co.kittitas.wa.us>; PublicHealth Inspectors <PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Codi Fortier <codi.fortier@co.kittitas.wa.us>; 'enviroreview@yakama.com' <enviroreview@yakama.com>; 'corrine_camuso@yakama.com' <corrine_camuso@yakama.com>; 'jessica_lally@yakama.com' <jessica_lally@yakama.com>; 'noah_oliver@yakama.com' <noah_oliver@yakama.com>; 'casey_barney@yakama.com' <casey_barney@yakama.com>; 'kozj@yakamafish-nsn.gov' <kozj@yakamafish-nsn.gov>; 'matj@yakamafish-nsn.gov' <matj@yakamafish-nsn.gov>; 'barh@yakamafish-nsn.gov' <barh@yakamafish-nsn.gov>; 'separegister@ecy.wa.gov' <separegister@ecy.wa.gov>; 'tebu461@ecy.wa.gov' <tebu461@ecy.wa.gov>; 'lowh461@ECY.WA.GOV' <lowh461@ECY.WA.GOV>; 'FormerOrchards@ecy.wa.gov' <FormerOrchards@ecy.wa.gov>; 'wendy.neet@ecy.wa.gov' <wendy.neet@ecy.wa.gov>; 'crosepa@ecy.wa.gov' <crosepa@ecy.wa.gov>; 'Scott.Downes@dfw.wa.gov' <Scott.Downes@dfw.wa.gov>; 'Jennifer.Nelson@dfw.wa.gov' <Jennifer.Nelson@dfw.wa.gov>; 'Elizabeth.Torrey@dfw.wa.gov' <Elizabeth.Torrey@dfw.wa.gov>; 'sepa@dahp.wa.gov' <sepa@dahp.wa.gov>; 'jorgenja@cwu.edu' <jorgenja@cwu.edu>; 'nelmsk@cwu.edu' <nelmsk@cwu.edu>; Jeremy Larson <jeremy.larson@co.kittitas.wa.us>; Steph Mifflin <stephanie.mifflin@co.kittitas.wa.us>; 'russell.mau@doh.wa.gov' <russell.mau@doh.wa.gov>; 'rivers@dnr.wa.gov' <rivers@dnr.wa.gov>; 'brenda.young@dnr.wa.gov' <brenda.young@dnr.wa.gov>; 'luke.warthen@dnr.wa.gov' <luke.warthen@dnr.wa.gov>; 'SEPACENTER@dnr.wa.gov' <SEPACENTER@dnr.wa.gov>;

From: [Adam Osbekoff](#)
To: [Jeremiah Cromie](#)
Subject: RE: PF-22-00002 KCFD #7 - Notice of Application
Date: Friday, October 7, 2022 1:58:39 PM

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Hello Jeremiah

As I have said in the past, this last week I reviewed over 360 projects plus have been in the field for two of those days and any number of meetings. I am glancing at some of these and trying to make snap judgements while doing a quick review via internal and external resources. We have concerns, the concerns remain no matter if they are minor or considerable concerns. I will stick with an IDP.

Thank you

Adam Osbekoff

From: Jeremiah Cromie [mailto:jeremiah.cromie@co.kittitas.wa.us]
Sent: Friday, October 7, 2022 1:04 PM
To: Adam Osbekoff <adam@snoqualmtribe.us>
Subject: RE: PF-22-00002 KCFD #7 - Notice of Application

Adam,

I am a bit confused as you sent comments last night about this same project (see attached). Can you please clarify?

Jeremiah Cromie
Planner II
Kittitas County
Community Development Services
411 N. Ruby Street; Suite 2
Ellensburg, WA 98926
Office: 509-962-7046
jeremiah.cromie@co.kittitas.wa.us

From: Adam Osbekoff <adam@snoqualmtribe.us>



October 12, 2022

Kittitas County Community Development Services
411 N. Ruby Street, Ste 2
Ellensburg, WA 98926

Attn: Jerimiah Cromie, Planner II

RE: PF-22-00002, KCFD #7
SR 970 milepost 2.57 left, Airport Rd. vicinity

We have reviewed the proposed project and have the following comments.

- The subject property is adjacent to State Route 970 (SR 970), a Managed Access Class 1 highway with a posted speed limit of 55 miles per hour. Access to the property is available via Airport Road. Direct access to SR 970 will not be permitted.
- Any proposed lighting must be direct down towards the site and away from SR 970.
- Stormwater or surface runoff generated by this proposal must be retained and treated on site. An approved utility permit is required for any discharge of water onto SR 970 right-of-way.
- Any outdoor advertising or motorist signing considered for this project will need to comply with state criteria. Please contact Trevor McCain of the WSDOT Headquarters Traffic Office for specifics. He can be reached at (360) 705-7282.
- In this location, WSDOT right-of-way extends 75' from the highway centerline. The proponent should be aware, any encroachment, including but not limited to grading, fencing, or landscaping, will not be allowed within the highway right-of-way.

Thank you for the opportunity to review and comment on this proposal. If you have any questions regarding this letter, please contact Jacob Prilucik at (509) 577-1635.

Sincerely,

Paul Gonseth, P.E.
Region Planning Engineer

PG: jjp/mnk
cc: SR 970, File #2020-001
Mike Krahenbuhl, Area 1 Maintenance Superintendent



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

Central Region Office

1250 West Alder St., Union Gap, WA 98903-0009 • 509-575-2490

October 19, 2022

Jeremiah Cromie
Kittitas County
411 N. Ruby St., Suite 2
Ellensburg, WA 98926

RE: PF-22-00002

Dear Jeremiah Cromie,

Thank you for the opportunity to comment on the Notice of Application for the KCFD #7 Manufactured Home. We have reviewed the application and have the following comment.

WATER RESOURCES

Groundwater Exempt Uses

In Washington State, prospective water users must obtain authorization from the Department of Ecology before diverting surface water or withdrawing ground water, with one exception. Ground water withdrawals of up to 5,000 gallons per day used for single or group domestic supply, up to 5,000 gallons per day used for industrial purposes, stock watering, and for the irrigation of up to one-half acre of non-commercial lawn and garden are exempt from the permitting process. Water use under the RCW 90.44.050 exemption establishes a water right that is subject to the same privileges, restrictions, laws and regulations as a water right permit or certificate obtained directly from Ecology.

Dust Control from a Well

If you plan to use water for dust suppression at your project site, be sure that you have a legal right. In Washington State, prospective water users must obtain authorization from the Department of Ecology before diverting surface water or withdrawing ground water, with one exception. Ground water withdrawals of up to 5,000 gallons per day used for single or group domestic supply, up to 5,000 gallons per day used for industrial purposes, stock watering, and for the irrigation of up to one-half acre of non-commercial lawn and garden are exempt from the permitting process. Water use under the RCW 90.44.050 exemption establishes a water right that is subject to the same privileges, restrictions, laws and regulations as a water right permit or certificate obtained directly from Ecology. Temporary permits may be obtainable in a short time-period. The concern of Water Resources is for existing water rights. In some instances water may need to be obtained from a different area and hauled in or from an existing water right holder.

If you have any questions or would like to respond to these Water Resources comments, please contact Christopher Kossik at (509) 379-1826 or email at christopher.kossik@ecy.wa.gov.

Sincerely,

Lucila Cornejo

Lucy Cornejo
SEPA Coordinator, Central Regional Office
(509) 208-4590
crosepacoordinator@ecy.wa.gov

202205053

From: [PublicHealth Inspectors](#)
To: [Jeremiah Cromie](#)
Subject: RE: PF-22-00002 KCFD #7 - Notice of Application
Date: Wednesday, October 19, 2022 3:27:34 PM

Jeremiah,

Environmental Health has reviewed this project. The applicant will need to submit an Individual Well Site Review application to approve the location of the well prior to drilling. Once the well is drilled, the applicant must apply for and obtain water adequacy approval before submitting plans to the building department for review.

Thank you,

Holly Erdman

From: Jeremiah Cromie <jeremiah.cromie@co.kittitas.wa.us>

Sent: Thursday, October 6, 2022 11:33 AM

To: Kim Dawson <kim.dawson@co.kittitas.wa.us>; George Long <long@kittcom.org>; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Toni Berkshire <toni.berkshire@co.kittitas.wa.us>; PublicHealth Inspectors <PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Codi Fortier <codi.fortier@co.kittitas.wa.us>; 'enviroreview@yakama.com' <enviroreview@yakama.com>; 'corrine_camuso@yakama.com' <corrine_camuso@yakama.com>; 'jessica_lally@yakama.com' <jessica_lally@yakama.com>; 'noah_oliver@yakama.com' <noah_oliver@yakama.com>; 'casey_barney@yakama.com' <casey_barney@yakama.com>; 'kozj@yakamafish-nsn.gov' <kozj@yakamafish-nsn.gov>; 'matj@yakamafish-nsn.gov' <matj@yakamafish-nsn.gov>; 'barh@yakamafish-nsn.gov' <barh@yakamafish-nsn.gov>; 'separegister@ecy.wa.gov' <separegister@ecy.wa.gov>; 'tebu461@ecy.wa.gov' <tebu461@ecy.wa.gov>; 'lowh461@ECY.WA.GOV' <lowh461@ECY.WA.GOV>; 'FormerOrchards@ecy.wa.gov' <FormerOrchards@ecy.wa.gov>; 'wendy.neet@ecy.wa.gov' <wendy.neet@ecy.wa.gov>; 'crosepa@ecy.wa.gov' <crosepa@ecy.wa.gov>; 'Scott.Downes@dfw.wa.gov' <Scott.Downes@dfw.wa.gov>; 'Jennifer.Nelson@dfw.wa.gov' <Jennifer.Nelson@dfw.wa.gov>; 'Elizabeth.Torrey@dfw.wa.gov' <Elizabeth.Torrey@dfw.wa.gov>; 'sepa@dahp.wa.gov' <sepa@dahp.wa.gov>; 'jorgenja@cwu.edu' <jorgenja@cwu.edu>; 'nelmsk@cwu.edu' <nelmsk@cwu.edu>; Jeremy Larson <jeremy.larson@co.kittitas.wa.us>; Steph Mifflin <stephanie.mifflin@co.kittitas.wa.us>; 'russell.mau@doh.wa.gov' <russell.mau@doh.wa.gov>; 'rivers@dnr.wa.gov' <rivers@dnr.wa.gov>; 'brenda.young@dnr.wa.gov' <brenda.young@dnr.wa.gov>; 'luke.warthen@dnr.wa.gov' <luke.warthen@dnr.wa.gov>; 'SEPACENTER@dnr.wa.gov' <SEPACENTER@dnr.wa.gov>; 'Garren.Andrews@dnr.wa.gov' <Garren.Andrews@dnr.wa.gov>; 'MARTIN.MAUNEY@dnr.wa.gov' <MARTIN.MAUNEY@dnr.wa.gov>; 'brooksideconsulting@gmail.com' <brooksideconsulting@gmail.com>; 'tribune@nkctribune.com' <tribune@nkctribune.com>; 'terry@nkctribune.com' <terry@nkctribune.com>; 'mbreckenridge@kvnews.com' <mbreckenridge@kvnews.com>; 'legals@kvnews.com' <legals@kvnews.com>; 'Deborah.j.knaub@usace.army.mil' <Deborah.j.knaub@usace.army.mil>; 'lhendrix@usbr.gov'



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: October 24, 2022
SUBJECT: PF-22-00002 KCFD #7

<p>ACCESS</p>	<ol style="list-style-type: none"> 1. Access will need to be from Parcel 065135 unless proof of easement can be shown through Parcel 635135 to Parcel 065135. 2. An approved access permit shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering an existing access. 3. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses. 4. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards. 5. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application.
<p>ENGINEERING</p>	<ol style="list-style-type: none"> 1. Except as exempted in Section KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). 2. A transportation impact analysis (TIA) shall be required for all development that will generate more than nine (9) peak hour vehicle trips. Please provide estimated traffic generation for peak hours to determine if a TIA will be required. (KCC 12.10.040(c)).
<p>SURVEY</p>	<p>No survey comments relating to this application.</p>

FLOOD	Parcel 065135 is not located in the special flood hazard area (100 Year Floodplain), and therefore a Floodplain Development Permit will not be required.
WATER MITIGATION/ METERING	Per KCC 13.35.027, all new uses of ground water require mitigation and metering. Parcel 065135 is located in the green zone and over the counter service area for the Kittitas County Water Bank. Water mitigation can be applied for at KCDPW once the well has been drilled. A Kittitas County water meter will also be required, after the building permit has been issued the meter can be picked up at KCDPW.