


KITTITAS COUNTY DEPARTMENT OF PUBLIC WORKS

TO: Chelsea Benner, Planner I
COPY: Taylor Gustafson, Planner III
DATE: October 19, 2018
FROM: Mark R. Cook, Director 
RE: SD-18-00001 Williams

Public Works has the following comments on the Williams substantial shoreline development permit application:

1. The bridge specifications provide no engineering calculations. Prior to bridge design approval, supporting calculations and a load rating are required.
2. We do not see anywhere in the application the type, quantity, source and composition of driveway and bridge approach abutment fill is detailed.
3. We note that a 100 year flow volume is referenced but there are no supporting calculations. The flow volume is a necessary component of validating bridge freeboard.
4. The application materials do not identify the access location for the proposed new driveway. It is unclear if the proposed new access location has any implications to floodplain or shoreline.