

## Lindsey Ozbolt

---

**From:** Brenda Larsen  
**Sent:** Friday, August 15, 2014 12:04 PM  
**To:** 'dick.landen@aol.com'; Lindsey Ozbolt  
**Subject:** SV-14-00001

Good morning,

In regard to the Landen Shoreline Variance noted above, I have the following comments/requirements:

The 'bridge' does not need to be rated for 75,000 lbs., but must be posted with the load capacity.  
The sign for the load capacity shall be no smaller than 6"x8" and may be brown in color with cream lettering.

Thank you,

*Brenda Larsen*  
*Fire Marshal*  
*509-962-7000*

---

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14