



DUNCANSON

Company, Inc.

TRANSMITTAL LETTER

DATE: May 11, 2010

DCI 00731.032

TO: Jeff Watson
Kittitas County Community Development Services
411 N. Ruby St., Suite 2
Ellensburg, WA 98926

FROM: Harold Duncanson

RE: Grove Short Plat SP-09-00001
Parcel: 20358

THE FOLLOWING DOCUMENTS ARE ENCLOSED:

<u>Quantity</u>	<u>Description</u>
1 Copy	Well pump test results
1 Copy	Well log
1 Copy	Satisfactory bacteria test
1 Copy	Satisfactory nitrate test

NOTES:

Please re-route to Health for signatures. Call me if you have any questions.

Harold Duncanson

From: Harold Duncanson [haroldd@duncansonco.com]
Sent: Wednesday, August 12, 2009 10:49 AM
To: 'Richard Wilson'
Subject: FW: Lower Green Canyon Road

Attachments: Grove Well Log & Inv.PDF



Grove Well Log &
Inv.PDF (482 ...

Rich:

Attached are the well log and the invoices for the new well in Ellensburg. The total is \$7670.16. The pump test data is below. I will forward current maps shortly per your request earlier today.

H

-----Original Message-----

From: jeremy@bachdrilling.com [mailto:jeremy@bachdrilling.com]
Sent: Friday, August 07, 2009 2:38 PM
To: haroldd@duncansonco.com
Subject: Lower Green Canyon Road


Harold

Here is the pump test. The new Bacteria test and IOC are still being finished.

Thank You
Jeremy Bach

Time	Static	Yield
0500	60	0
0515	65	10
0530	71	15
0545	72	15
0600	72	15
0630	72	15
0700	72	15
0730	72	15
0800	72	15
0830	72	15
0900	72	15
0905	60	0

Static recovery instantaneous; Grey Bach:#1778.



VALLI Environmental Laboratory

Washington State Certified Lab #153 - DOE Accredited Lab C345
 PRIMARY INORGANIC CHEMICALS (IOC's) REPORT

Lab/Sample No: 153-73115		Date Collected: 07/31/09		DOH Source No:					
Date Received: 07/31/09		Date Reported: 08/19/09		Supervisor: BKO					
Date Digested: 07/31/09		Date Analyzed: See Below		Analyst: See Below					
County: KITTITAS				Invoice#: 14484					
Sample Location: Well Head									
Send Report To:			Sample Information		Matrix: Drinking Water				
Bach Pump Company 2091 Orchard Rd Ellensburg, WA 98926			L. Green Kittitas						
DOH#	Analytes	Results	Units	SRL	Trigger	MCL	Method	Analyzed	Analyst
4	Arsenic	ND	mg/L	0.002	0.01	0.01	EPA 200.9	08/19/09	BKO
5	Barium	<0.1	mg/L	0.1	2	2	SM 3113B	08/11/09	046
6	Cadmium	ND	mg/L	0.002	0.005	0.005	EPA 200.9	08/17/09	BKO
7	Chromium	ND	mg/L	0.01	0.1	0.1	EPA 200.9	08/17/09	BKO
11	Mercury	ND	mg/L	0.0002	0.002	0.002	EPA 245.1	08/11/09	046
12	Selenium	ND	mg/L	0.005	0.05	0.05	EPA 200.9	08/17/09	BKO
110	Beryllium	ND	mg/L	0.003	0.004	0.004	EPA 200.9	08/17/09	BKO
111	Nickel	ND	mg/L	0.04	0.1	0.1	EPA 200.9	08/18/09	BKO
112	Antimony	ND	mg/L	0.005	0.006	0.006	EPA 200.9	08/18/09	BKO
113	Thallium	ND	mg/L	0.002	0.002	0.002	EPA 200.9	08/18/09	046
116	Cyanide	ND	mg/L	0.05	0.2	0.2	SM 4500CN E	08/04/09	BKO
19	Fluoride	ND	mg/L	0.2	2	4	SM 4500F C	08/03/09	DCO
114	Nitrite - N	ND	mg/L	0.5	0.5	1	SM 4500NO2 B	07/31/09	DCO
20	Nitrate - N	5.02	mg/L	0.5	5	10	SM 4500NO3 D	07/31/09	DCO
161	Total Nitrate / Nitrite	5.02	mg/L	0.5	5	10	EPA 353.3	07/31/09	DCO
8	Iron	0.66	mg/L	0.1	0.3	0.3	EPA 200.9	07/31/09	BKO
10	Manganese	ND	mg/L	0.01	0.05	0.05	EPA 200.9	08/19/09	BKO
13	Silver	ND	mg/L	0.01	0.1	0.1	EPA 200.8	08/19/09	BKO
21	Chloride	7.5	mg/L	20	250	250	SM 4500Cl-B	08/06/09	RAO
22	Sulfate	ND	mg/L	10	250	250	EPA 375.4	08/05/09	BKO
24	Zinc	ND	mg/L	0.2	5	5	EPA 200.8	08/11/09	046
14	Sodium	9.6	mg/L	5			EPA 200.7	08/11/09	046
15	Hardness	126	mg/L	10			SM 2340C	08/04/09	DCO
16	Conductivity	267	µS/cm	1	700	700	SM 2510B	08/05/09	DCO
17	Turbidity	10.9	NTU	0.1	1	1	EPA 180.1	08/14/09	DCO
18	Color	26	color units	1	15	15	SM 2120B	08/03/09	DCO
26	Total Dissolved Solids	131	mg/L	10	500	500	SM 2340C	08/19/09	BKO

201 East D Street Yakima, WA 98901 509-575-3999 Fax: 509-575-3068

73115-ioc