



To Protect and Promote the Health and the Environment of the People of Kittitas County

November 25th 2009

Jeff Watson, Staff Planner
Community Development Services
411 N Ruby Street, Suite 2
Ellensburg, WA 98926

RE: Hawkins Short Plat SP-09-00018

Dear Mr. Watson,

Thank you for the opportunity to comment on the Hawkins Short Plat, SP-09-00018. All residential well connections serving the proposed lots shall be required to have meters installed. Metering results shall be recorded in a manner consistent with Kittitas County and the State of Washington, Department of Ecology requirements. This requirement to meter only applies if you rely upon the RCW 90.44.050 exemption from permitting through ecology.

The final plat notes shall include the following two statements:

"The approval of this division of land includes no guarantee that there is a legal right to withdraw groundwater within the land division. The approval of this division of land provides no guarantee that use of water under the ground water exemption (RCW 90.44.050) for this plat or any portion thereof will not be subject to curtailment by the Department of Ecology or a court of law. "


AND

"Metering will be required on all new residential well connections and metering results shall be recorded in a manner consistent with Kittitas County and Washington State Department of Ecology requirements."

The Public Health Department's recommendation shall state that final approval be conditioned upon the developer/owner of the plat providing proof of water availability. Water availability can be provided through several different ways depending on the source of water proposed.

If a public water system is proposed for the plat, the public water system information shall be submitted and reviewed by Kittitas County Public Health Department or the State of Washington, Department of Health which includes final issuance of the well ID number to meet the water availability requirement for plat approval.

**Kittitas County
Public Health Department**
507 N. Nanum Street, Suite 102
Ellensburg, WA 98926
T: 509.962.7515
F:509.962.7581



www.co.kittitas.wa.us/health/

**Environmental
Health Services**
507 N. Nanum Street, Suite 102
Ellensburg, WA 98926
T: 509.962.7515
F:509.962.7581



To Protect and Promote the Health and the Environment of the People of Kittitas County

If individual wells are proposed for the parcels and there is an existing well located on the plat, a well log from the State of Washington, Department of Ecology and a recent passing bacteriological test will meet the water availability requirement. If there is not currently an existing well located on the plat, a well must be drilled and flow capacity must be known, bacteriological and nitrate tests must be performed and satisfactory to current health standards before the public health department may recommend final approval. If preliminary approval is sought, the applicant must demonstrate evidence of the water supply type that they intend on making available to the proposed lots and that adequacy will be achieved through a water availability report. Final approval will be conditioned upon the conditions of preliminary approval, a well must be drilled, flow capacity known, water storage mitigations resolved, bacteriological and nitrate tests must be performed and satisfactory from all wells to be used for domestic use before final approval can be recommended.

A Soil log or site and soil evaluation must be preformed prior to the Public Health Department recommending preliminary approval of the plat. The Public Health Department's approval of the soil logs will meet the septic availability requirement for recommending preliminary plat approval.

At this time the application does not contain sufficient information to make a determination of adequate water availability or soil assessment to determine the land area is suitable for onsite sewage systems. The above mentioned items need to be submitted to the Public Health Department in order for the plat application to be recommended for approval.


If you should have any questions or comments, please feel free to contact me at (509) 962-7515.

Sincerely,

A handwritten signature in blue ink that reads "James Rivard".

James Rivard,
Environmental Health Supervisor
Kittitas County Public Health

**Kittitas County
Public Health Department**
507 N. Nanum Street, Suite 102
Ellensburg, WA 98926
T: 509.962.7515
F:509.962.7581



www.co.kittitas.wa.us/health/

**Environmental
Health Services**
507 N. Nanum Street, Suite 102
Ellensburg, WA 98926
T: 509.962.7515
F:509.962.7581