

Corrected copy

WATER WELL REPORT

Start Card No. W085527

Unique Well I.D. # AC050

Water Right Permit No.

STATE OF WASHINGTON

(1) OWNER: Name REILLEY, J.P. Address P.O. BOX 1265 ELLENBURG, WA 98926-1265

(2) LOCATION OF WELL: County KITTITAS - NE 1/4 NE 1/4 Sec 10 T 18 N., R 18 W

(2a) STREET ADDRESS OF WELL (or nearest address),

(3) PROPOSED USE: DOMESTIC (10) WELL LOG

(4) TYPE OF WORK: Owner's Number of well (If more than one) Method: ROTARY
 NEW WELL

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

(5) DIMENSIONS: Diameter of well 6 inches
 Drilled 180 ft. Depth of completed well 180 ft.

(6) CONSTRUCTION DETAILS:
 Casing installed: 6" Dia. from 0 to 2 ft. to 178 ft.
 STEEL CASING " Dia. from ft. to ft.
 " Dia. from ft. to ft.

MATERIAL	FROM	TO
BOULDERS AND COBBLES	0	6
SAND AND CLAY	6	12
BROWN CLAY	12	44
BOULDERS AND BASALT	44	52
BROWN CLAY	52	54
BASALT BOULDERS GRAVEL	54	58
BASALT AND SAND	58	88
SANDY CLAY	88	97
BASALT AND GRAVEL	97	133
BROWN CLAY	133	149
BASALT BOULDERS WITH WATER	149	155
BROWN CLAY	155	165
BASALT GRAVEL WITH WATER	165	180

Perforations: NO
 Type of perforator used
 SIZE of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

Screens: NO
 Manufacturer's Name
 Type Model No.
 Diam. slot size from ft. to ft.
 Diam. slot size from ft. to ft.

Gravel packed: NO
 Gravel placed from ft. to ft. Size of gravel

Surface seal: YES To what depth? 18 ft.
 Material used in seal BENTONITE
 Did any strata contain unusable water? NO
 Type of water? Depth of strata ft.
 Method of sealing strata off OVERBORE

(7) PUMP: Manufacturer's Name Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
 Static level 57 ft. below top of well Date 08/22/96
 Artesian Pressure lbs. per square inch Date
 Artesian water controlled by

Work started 08/22/96 Completed 08/22/96

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?
 Yield: gal./min with ft. drawdown after hrs.

Recovery data
 Time Water Level Time Water Level Time Water Level

Date of test / /
 Bailer test gal/min. ft. drawdown after hrs.
 Air test 25 gal/min. w/ stem set at 160 ft. for 1 hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? NO

WELL CONSTRUCTOR CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME PONDEROSA DRILLING
 (Person, firm, or corporation) (Type or print)

ADDRESS E 6010 BROADWAY

[SIGNED] *Judy Carpenter* License No. 1900

Contractor's
 Registration No. PO-MD-EI*248JE Date 08/29/96

