



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Jeff Watson, Planner II
FROM: Christina Wollman, Planner III *CW*
DATE: October 13, 2015
SUBJECT: Request More Information
Filbert Estates Short Plat SP-15-00004

The existing bridge over the canal must meet the guidelines of KCC 12.07.010 and 12.07.030. The bridge must be the same width as the private road, which will have a width requirement of 22'. The existing bridge appears to be approximately 14' wide. The applicant shall provide additional information on how they intent to meet this requirement. This information will be required prior to the issuance of conditional preliminary approval.