



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Kittitas County Public Works Plan Review Team
DATE: March 23, 2022
SUBJECT: SE-22-00004 Pocus Holdings

SEPA Application Comments

- Grading over 100 cubic yards of material requires a grading permit. Any grading over 500 cubic yards of material will require engineered grading and storm water plans. Please see Kittitas County Code Chapter 14.05.
- An access permit has been submitted to Public Works.

Please contact Kittitas County Public Works (509) 962-7523 with any questions.