



# **KITTITAS COUNTY**

## **DEPARTMENT OF PUBLIC WORKS**

---

### **MEMORANDUM**

---

---

TO: Community Development Services  
FROM: Kittitas County Public Works Plan Review Team  
DATE: March 23, 2022  
SUBJECT: SE-22-00005 Haase

#### **SEPA Application Comments**

- An access/address permit is required for this proposal. Please see Kittitas County Code Chapter 12.04 and 12.05 for requirements.
- Grading over 100 cubic yards of material requires a grading permit. Any grading over 500 cubic yards of material will require engineered grading and storm water plans. Please see Kittitas County Code Chapter 14.05.

Please contact Kittitas County Public Works (509) 962-7523 with any questions.