



KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Fire Marshal (509) 962-7000 Deputy Fire Marshal (509) 962-7657

November 28, 2022

To: Whom It May Concern

Re: SE-22-00065 Bowers Field Ph. 1

Regarding the above application, the KCFMO does not see any issue with approving this project and its phases as the process continues. The approval of this project is contingent upon construction of all structures complying with Chapter 20 of the IFC and any applicable codes/standards from the NFPA.

These codes may require installation automatic sprinkler systems, fire alarm systems, fire extinguishing equipment, etc. Additionally, the egress of these structures shall comply Chapter 10 of the IFC and applicable NFPA standards and codes.

Additionally, structures constructed as part of this project shall be subject to the KCFMO Wildland Urban Interface Code evaluation/inspection.

This is not a full description of applicable codes and standards and the KCFMO reserves the right to add requirements as needed as the project progresses.

Thank you for your time.

Deputy Fire Marshal,
Joseph A Dietzel