



To Protect and Promote the Health and the Environment of the People of Kittitas County

Subdivision Comments

To: Chace Pedersen, Planner I

From: Kim Shilley, Public health Tech, Joe Rainwater-Cummings, Environmental Specialist II

Date: 04/27/2023

RE: SE-23-00009 Nelson View

Thank you for the opportunity to comment on the above-mentioned project regarding water and septic requirements to comply with Kittitas County Public Health Department's Water Resources and Environmental Health requirements.

Findings

On Site Sewage

Finding 1

Any on-site septic systems that are to be utilized for wastewater management must adhere to the standards set by both the Washington Administrative Code, and Kittitas County Code. In accordance with KCC 13.04.090, a minimum of one soil log for each proposed lot where individual sewage disposal systems are contemplated must be completed. If community drain fields are to be utilized, soil logs must be done in the proposed locations of each(See Conditions A-2).

Water

Finding 1

Proposed short plat shared wells will be used. If the intention is to utilize a shared well, a signed, notarized, and filed shared well users agreement will also need to be provided before the short plat is finalized. If shared wells are to be utilized, the wells must be drilled a minimum of 50 feet from any proposed property line and a signed, notarized and recorded shared waters users' agreement for each shared well must be submitted to our office prior to final plat approval. The applicant must prove physical availability of water for all new uses of water proposed lots of this project, which can be provided by (See Condition A-1) a well log or 4 hour draw down test as proof of water availability for each new well proposed. All persons who are



To Protect and Promote the Health and the Environment of the People of Kittitas County

making applications for land use including but not limited to short plats must comply with KCC Chapter 13.35.020.

Additional information Required (Prior to Preliminary Plat Approval)

- List what is needed for preliminary plat approval

Additional information Required (Prior to Final Plat Approval)

On-site sewage

A soil log is needed for the proposed lots

Water

A signed and recorded shared water user's agreement between proposed lots is needed. Along with a current water right for the proposed lots.

A-1 13.35.020(b) requires proof of adequate water supply, which can be submitted through a well log or 4 hour draw down test if an existing well is used and is older than 10 years. If shared wells are used, a signed, notarized, and recorded shared well-users agreement must be submitted. All individual and shared wells must meet the distance requirement of 50 feet from the property line, 50 feet from the septic tank and 100 feet from the drain field as per Kittitas County Critical Areas Ordinance 17A.08.25, and KCC Chapter 13.

A-2 Soil logs are required for lots. In accordance with KCC 13.04.090, a minimum of one soil log for each proposed lot where individual sewage disposal systems are contemplated must be completed prior to final plat approval. Soil logs can be scheduled at <https://www.co.kittitas.wa.us/health/septic-inspection.aspx>. Soil logs are performed in accordance with WAC 246.272A

Final Plat Notes

REQUIRED PLAT NOTES

1. The approval of this division of land provides no guarantee that use of water under the ground water exemption (RCW 90.44.050) for this plat or any portion thereof will not be subject to curtailment by the Department of Ecology or a court of law. (settlement agreement)