



# KITTITAS COUNTY

## DEPARTMENT OF PUBLIC WORKS

### MEMORANDUM

**TO:** All Staff  
**FROM:** Public Works Plan Review Team  
**DATE:** October 11<sup>th</sup>, 2023  
**SUBJECT:** Public Works Comments: VA-23-00008 Hendrix

<b>ACCESS</b>	<ol style="list-style-type: none"> <li>1. An approved access permit shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering an existing access.</li> <li>2. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.</li> <li>3. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards.</li> <li>4. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application.</li> </ol>
<b>ENGINEERING</b>	<p>Except as exempted in Section KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CC)</p>
<b>SURVEY</b>	<ol style="list-style-type: none"> <li>1. Given the tight tolerances, it is highly recommended that the garage be staked out by a land surveyor licensed in the State of Washington.</li> <li>2. Given the tight tolerances, no portion of swinging doors, eaves, or building footings should extend into the remaining 7.5' setback.</li> </ol>
<b>TRANSPORTATION CONCURRENCY</b>	<p>No transportation concurrency application will be required for this project. (KAH)</p>
<b>FLOOD &amp; WATER MITIGATION/ METERING</b>	<p>No comments. (SC)</p>