

## KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Office (509) 962-7657 Fax (509) 962-7682

INFORMATIONAL BULLETIN FM-07

# **Fire Marshal LPG Tank Inspections**

### When does my Building/Mechanical Permit require an inspection from the Fire Marshal's Office?

A separate inspection from the Kittitas County Fire Marshal's Office is required anytime your building or mechanical permit involves the installation or modification of a liquid petroleum gas (LPG) tank.

#### What inspections are required?

The Kittitas County Fire Marshal's Office will inspect:

- Setback distances for the tank
- Pressure Test for exterior LPG piping
- Burial depth and installation of tracer-wire for LPG piping
- Inert backfill material free of rocks and debris
- Anchoring for flood plain installation (Flood Permit Required)

#### How do I schedule an inspection from the Fire Marshal's Office?

You may schedule an inspection 1 of 2 ways.

- 1. Call the Community Development Services Inspection Request Line at 509-962-7694 and request a Fire Marshal LPG Inspection, or
- 2. Visit the County's Website at: http://www.co.kittitas.wa.us/cds/request.asp

The Kittitas County Fire Marshal's Office only inspects exterior gas piping and tank assemblies. All piping and appliance inspections on the interior of the structure must be requested through Kittitas County Community Development Services.

