

## FIRE LIFE SAFETY INSPECTION REPORT

Occupancy/ FD #: 002-029-0001 Map #: 17-19-34	1055-0002 Inspection Date: 2-6-2014	
Business Name: Harvestco Fabricators Inc Business phone number: 925-9345		
Address: 740 Dodge Rd Ellensburg, WA 98926 Ma	ailing Address: 740 Dodge Rd Ellensburg, WA 98926	
Type of Business: Equipment mfg and repair B	Business contact person: Galen Flory	
Occ Group: F-1 Sq. Ft: 6000 Const. Type: V-B Sprinklers: no Alarms: no Fixed: no		
Permits: <b>yes</b> Special Notes:		

A fire inspection has been conducted on your property. During this inspection conditions affecting fire safety were noted. *In accordance with the International Building Code and International Fire Code, it is necessary that the items listed below be given your prompt attention.* 

A. Exterior Assessment	E. Fire Alarm System	I. Kitchen Suppression	
1 - Building number not posted	1 - Annual Service needed	1 - Cleaning of hood and duct	
2 - Obstructed FDC	2 - Devices obstructed	2 - Illegal cooking operation	
3 - Obstructed fire hydrant	3 - Alarm Maintenance	3 - Six month service needed	
4 - Gas meter protection	F. Flammable/Combustible	J. Automatic Sprinkler	
5 - Storage proximity	1 - Storage cabinet	1 - Annual service needed	
6 - Storage under eaves	2 - Improper housekeeping	2 - FDC cap needed	
B. Exits	3 - No storage area	3 - Hanging material	
1 - Exit travel	4 - Close to heating appliance	4 - Sprinkler clearance	
2 - Exits obstructed	5 - Fueled equipment	5 - Provide sprinkler protection	
3 - Panic hardware	6 - Oily rags	6 - Damaged/Painted heads	
4 - Number of exits	7 - Compressed gas tanks	7 - Spare heads and/or wrench	
5 - Unapproved locking devices	8 - Equipment rooms	K. Fuel Dispensing	
6- Openable without tight grasping or twisting	9- Secondary Containment	1 - Fire extinguisher	
7-Remove Bolt Locks or Dead Bolts		2 - Emergency shutoff	
C. Exit Lighting and Signs	G. Electrical	3 - Provide signage	
1 - Exit signs battery backup	1 - Extension cord usage	4 - Replace hoses	
2 - Exit signs required	2 - Electrical panel labeling	L. Compressed Gas	
3 - Emergency lighting	3 - Portable heaters	1-Cylinders shall be secured	
4 - Exit sign burnt out	4 - Improper power strip usage	2- Protective caps shall be in place when not in use.	
5 - "This door to remain unlocked" sign	5 - Power Panel obstructed	M. Storage	
D. Extinguishers	6 - No cover plate	1-Ceiling Clearance	
1 - Class K extinguisher	7 - Multi-plug adapter	2- Equipment rooms	
2 - Number of extinguishers		3- Storage under stairs or in attic	
3 - Extinguisher placement	H. Fire Walls and Doors	N. Other corrections required	
4 - Extinguisher obstructed	1 - Restrained fire door	1-See detailed report	
5 - Extinguisher maintenance	2 - Breached wall or ceiling		
6 - Signs indicating location	3 - Fire assembly needs repair	X. No apparent Violations Noted	
7- Minimum size 2A-10BC		1 - No apparent Violations	

Remarks:

This Fire Inspection report also serves as your invoice. Please remit payment in the amount of \$163.87 within 30 days.

Inspector's Name: Bill Steele- DFM

Inspector's Phone #: 962-7657

E-mail address: harvestco@fairpoint.net

Received by e-mail

Compliance with the preceding requirements shall be effective immediately.

A re-inspection shall be conducted on/or after \_\_\_\_\_ days to verify full compliance.

You are hereby notified to remedy the conditions as stated above immediately.

After the conditions have been abated, mail a copy of the notice within \_\_\_\_\_ days including a signature certifying completion.

I CERTIFY THAT THE VIOLATIONS SPECIFIED ABOVE HAVE BEEN CORRECTED.

PRINT NAME